



---

ENGINEERING DEPARTMENT

Civil/Traffic/Parking/Signal & Lighting/Sign and Pavement Marking  
Daniel J. Moeglin, P.E., S.I., City Engineer  
2436 -30th Street N.E. / Canton, Ohio 44705  
PH (330) 489-3381 / FAX (330) 489-3337

**ADDENDUM #4**

February 13, 2015

TO: PROSPECTIVE BIDDERS  
RE: **GP 1114 Allenford SE 72" Sanitary Sewer Protection Project**

---

Addendum #4 for bid opening scheduled for February 18, 2015. This addendum consists of one change and three clarifications.

**Change:**

The bid opening is being postpone a second time for one week due to omissions and clarifications to the plans as detailed in the following paragraphs. The new bid opening is scheduled for **February 25, 2015 at 2:00 pm.**

**First (Clarification):**

Technical specification Section 02538, Sanitary Sewer System, issued in Addendum 3 is a revision of the spec issued in Addendum 2. We are clarifying that Addendum 3 revision deletes SANITARY SEWER SYSTEM, Part 3.5 FIELD QUALITY CONTROL, Sub-section E. "Infiltration/Exfiltration Test: Test in accordance with ASTM C969, latest edition." We just need the joint test that is in Part 3.5.A (Joint Test: Test in accordance with ASTM 1103, latest edition.)

**Second (Clarification):**

Specifications 02-00 and 03-00 do not pertain to any items in the plans. These are standard supplemental specifications that the City uses. We wish to clarify that we wish to keep them in the bid for reference.

**ADDENDUM #4 Continued**

**Third (Clarification):**

Specification Section 0298 TEMPORARY BYPASS PUMPING, PART 4 GENERAL, Sub-section 2.c. read, " Approximate wet-weather flow to be pumped from the 72" sewer during second stage bypassing is 40 mgd." We wish to clarify that all bidder should use 40 mgd for basis of the bid. The capacities for the pipe as shown on page 26 of the plans show PEAK capacities, and not maximum capacities.

Please sign this Addendum No. 4 at the bottom of this page as proof of receipt. Attach this addendum to the inside front cover of your submission. The Director reserves the right to accept or disqualify the bid if you do not include this addendum.

Respectfully,



Steven L. Henderson  
City of Canton Construction Manager

\_\_\_\_\_  
BIDDERS AUTHORIZED SIGNATURE

\_\_\_\_\_  
DATE

\_\_\_\_\_  
NAME / TITLE (Printed or Typed)